


ProSoft

PROGRAMMABLE LOGIC CONTROLLER PROGRAMMING SOFTWARE



USER MANUAL



P.O.Box 24
STANFIELD 3613
SOUTH AFRICA

Tel: +27 (031) 7028033
Fax: +27 (031) 7028041
Email: proconel@proconel.com
Web: www.proconel.com

27/07/2005 V3.0

Disclaimer

Procon Electronics makes no representations or warranties with respect to the contents hereof. In addition, information contained herein are subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, Procon Electronics assumes no responsibility, express or implied, for errors or omissions or any damages resulting from the use of the information contained in this publication.

All trademarks belong to their respective owners.

TABLE OF CONTENTS

1.	AN OVERVIEW OF THE ProSoft PLC PROGRAMMING SOFTWARE PACKAGE.....	6
2.	INSTALLING ProSoft	6
3.	Setting Up ProSoft.....	8
3.1	STARTUP	8
3.2	CREATING A NEW PROJECT	8
3.3	SETUP PC COMMUNICATIONS	8
3.4	File->Get Prog. Info	9
3.5	ENTER LADDER EDIT MODE	9
3.6	EDIT->TAGS	9
3.7	EDIT->Communications	11
3.8	EDIT->Comms Settings	12
4.	LADDER PROGRAMMING.....	13
4.1	LADDER TOOLBAR ELEMENTS.	13
4.1.1	Horizontal Wire	13
4.1.2	Vertical Wire	13
4.1.3	Normally Open Contact.....	13
4.1.4	Normally Closed Contact	13
4.1.5	Positive Edge Contact.....	14
4.1.6	Negative Edge Contact	14
4.1.7	Function Contact.....	14
4.1.8	Normal Output.....	14
4.1.9	Inverted Output.....	14
4.1.10	Set Output.....	14
4.1.11	Reset Output	14
4.1.12	Function Output	14
4.1.13	Comment	15
4.1.14	Delete Element	15
4.1.15	Delete Line	15
4.1.16	Insert Line.....	15
4.1.17	Copy Lines.....	15
4.1.18	Move Lines	15
4.1.19	Shift Element Right	15
4.1.20	Shift Element Left	15
4.2	CREATING A SAMPLE PROGRAM.....	16
4.2.1	Step 1	16
4.2.2	Step 2.....	16
4.2.3	Step 3.....	16
5.	COMPILING.....	17
6.	PROGRAMMING THE PLC.....	18
7.	DEBUGGING THE PLC	19
7.1	View I/O status in Debug Mode.....	19
7.2	View Memory in Debug Mode.....	20
7.3	Start/Stop PLC in Debug Mode.....	20
8.	LADDER LOGIC.....	21
8.1	PLC Operation.....	21
8.2	PLC Memory.	22
8.3	Basic Rung Configurations.....	24
8.4	Ladder Program Processing.....	26
8.5	Ladder Programming Elements	27
8.5.1	Ladder Inputs - Normally Open/Closed Contact	27
8.5.2	Ladder Inputs - Positive/Negative Edge Contact.....	27
8.5.3	Ladder Inputs – Function Contact	28
8.5.3.1	Function Contact – (Mem = Mem)	28
8.5.3.2	Function Contact – (Mem = Const)	29
8.5.3.3	Function Contact – (Mem /= Mem)	29
8.5.3.4	Function Contact – (Mem /= Const)	29

8.5.3.5	Function Contact – (Mem >= Mem).....	30
8.5.3.6	Function Contact – (Mem >= Const).....	30
8.5.3.7	Function Contact – (Mem < Mem).....	30
8.5.3.8	Function Contact – (Mem < Const).....	31
8.5.4	Ladder Outputs – Normal/Inverted Output.....	31
8.5.5	Ladder Outputs – Set/Reset Output.....	31
8.5.6	Ladder Outputs – Standard Functions.....	33
8.5.6.1	Function Output – (Timer 0.1Sec & Timer 0.01Sec).....	33
8.5.6.2	Function Output – (TimerA 0.1Sec and TimerA 0.01Sec).....	34
8.5.6.3	Function Output – (Counter).....	35
8.5.6.4	Function Output – (Cntr Up/Down – Type 1).....	35
8.5.6.5	Function Output – (NOP).....	36
8.5.6.6	Function Output – (END).....	36
8.5.6.7	Function Output – (LD Load Accumulator).....	36
8.5.6.8	Function Output – (OUT).....	37
8.5.6.9	Function Output – (AND).....	38
8.5.6.10	Function Output – (OR).....	39
8.5.6.11	Function Output – (XOR).....	40
8.5.6.12	Function Output – (CMP).....	41
8.5.6.13	Function Output – (ADD).....	41
8.5.6.14	Function Output – (SUB).....	42
8.5.6.15	Function Output – (MUL).....	42
8.5.6.16	Function Output – (DIV).....	43
8.5.6.17	Function Output – (INC).....	43
8.5.6.18	Function Output – (DEC).....	43
8.5.6.19	Function Output – (INV).....	44
8.5.6.20	Function Output – (MOV).....	44
8.5.6.21	Function Output – (SHL).....	44
8.5.6.22	Function Output – (SHR).....	45
8.5.6.23	Function Output – (CALL).....	46
8.5.6.24	Function Output – (SUBR).....	46
8.5.6.25	Function Output – (RET).....	46
8.5.6.26	Function Output – (RAND).....	47
8.5.7	Ladder Outputs – Advanced Functions.....	48
8.5.7.1	Function Output – (LDD Load Double).....	48
8.5.7.2	Function Output – (OUTD Out Double).....	49
8.5.7.3	Function Output – (ANDD).....	49
8.5.7.4	Function Output – (ORD).....	50
8.5.7.5	Function Output – (XORD).....	50
8.5.7.6	Function Output – (CMPD).....	51
8.5.7.7	Function Output – (ADDD).....	51
8.5.7.8	Function Output – (SUBD).....	51
8.5.7.9	Function Output – (MULD).....	52
8.5.7.10	Function Output – (DIVD).....	52
8.5.7.11	Function Output – (INCD).....	52
8.5.7.12	Function Output – (DECD).....	52
8.5.8	Ladder Outputs – Float Functions.....	53
8.5.8.1	Function Output – (LDF Load Float).....	53
8.5.8.2	Function Output – (OUTF Out Float).....	53
8.5.8.3	Function Output – (CMPF Compare Float).....	53
8.5.8.4	Function Output – (ADDF).....	54
8.5.8.5	Function Output – (SUBF).....	54
8.5.8.6	Function Output – (MULF).....	54
8.5.8.7	Function Output – (DIVF).....	54
8.5.8.8	Function Output – (BTOF).....	54
8.5.8.9	Function Output – (FTOB).....	54
8.5.8.10	Function Output – (PWRF).....	55
8.5.9	Ladder Outputs – Trigonometric Functions.....	55
8.5.9.1	Function Output – (ACOSF).....	55
8.5.9.2	Function Output – (ASINF).....	55

8.5.9.3	Function Output – (ATANF).....	55
8.5.9.4	Function Output – (COSF).....	55
8.5.9.5	Function Output – (SINF).....	55
8.5.9.6	Function Output – (TANF).....	56
8.5.9.7	Function Output – (SQRTF).....	56
8.5.9.8	Function Output – (RADF).....	56
8.5.9.9	Function Output – (DEGF).....	56
8.5.9.10	Function Output – (LOGF).....	56
8.5.9.11	Function Output – (EXPF).....	56
8.5.10	Ladder Outputs – Communications Functions.....	57
8.5.10.1	Function Output – Serial Communications – (COMM).....	57
8.5.10.2	Function Output – TCP/IP Communications – (TCOM).....	59
9.	LADDER PROGRAM EXAMPLES.....	62
9.1	Motor Control Example.....	62
9.2	Garage Door Example.....	64
9.3	Up/Down Counter Example.....	67

1. AN OVERVIEW OF THE ProSoft PLC PROGRAMMING SOFTWARE PACKAGE

The ProSoft PC software package is used to configure and program PLC products manufactured by Procon Electronics.

The software runs on a Windows XP operating system and has been written to be very user friendly and quick to learn. Most of the programming can be performed with only mouse operations.

ProSoft has built in intelligence to auto configure itself according to the type of PLC being used. This includes selecting the correct amount of I/O memory, and variable memory depending on the capabilities of the PLC.


The PLC program being designed is 'written' in the well known ladder logic language and saved as a project file. This project file holds the program, all the auto parameters for the PLC type chosen, and the tag names the user has given to the I/O. The software combines ladder logic with function blocks to allow the use of mathematical functions and manipulation of analog variables.

ProSoft has a modbus master configuration section which allows easy setting up of the PLC for communications. This feature is only enabled if the PLC supports this function.

2. INSTALLING ProSoft


Step 1

Insert the CD-ROM into the CD Drive. The software installer should start without assistance. If the software installer does not start, browse to setup.exe in the root directory of the CD and double-click on it; then click on OK to start the setup.



Step 2

Select the Installation Folder if required. It is recommended that the suggested folder is used for the installation.



Step 3

Finally confirm the setup and complete the setup procedure. You will notice that a shortcut has been added to the user Desktop. Remove the CD-ROM from the CD Drive.

3. Setting Up ProSoft

3.1 STARTUP

To launch the ProSoft Application Program click on the shortcut on the Desktop called ProSoft.

This will load the startup screen which is blank until a project has been created or opened.

3.2 CREATING A NEW PROJECT

To create a new project click on the **file** menu item with the mouse. A drop down sub-menu will appear on the screen. Click on **new** and a box will appear on the screen which asks you to select the PLC type. It is important that you select the correct type according to the hardware you want to program. This is because the auto-configuration will initialize the I/O and memory according to the type of PLC you have, and this configuration is very likely to be different with other PLC types.

Once the PLC type has been selected, click on **select** to continue. A new box will now open on the screen which asks for the file name of the project you want to create. You must also select a suitable working directory for your projects at this point. After typing in the project name (no extension is required) click on **save** and you will now have created a project.


You will notice that at the top left of the screen the project name and path is displayed, along with the PLC type.

3.3 SETUP PC COMMUNICATIONS

Click on the **file** menu item again and this time click on **Setup->PC Comms**. This action will open a box on the screen which allows you to enter the programming port address (ID) of the PLC and also set the Comm Port of the PC. All PLC's are initially configured for an ID of 1, so there is no need to alter this parameter at the moment. The PC Comm port must be changed according to the RS232 port that the PLC is to be connected to.

3.4 File->Get Prog. Info

When you click on the **File** menu item and then the **Get Prog. Info** button a box will open on the screen which reads the program name from the PLC, date created and the date downloaded. This can be used to inform the user at a later date which program has been downloaded into the PLC. Initially when the PLC is new and there is no program loaded this data will not be available. Click on the **Close** button to close the box.



3.5 ENTER LADDER EDIT MODE

Click on the **ladder** menu item to go into the ladder edit mode. This will enable other menu items and the toolbar for selecting programming items will also become active.


You will notice a yellow box appear on the screen. This box indicates the cell in the screen which was last edited.

3.6 EDIT->TAGS

Now that the software is in Ladder Edit mode the first step is to edit the description of the I/O tags that are going to be used in the program. This step is not mandatory but will help you better identify the inputs and outputs if you give them a meaningful name and description.

Click on the menu item **Edit** and then **Tags** to open the box which displays the I/O tags. The I/O tags are divided into categories. These categories are: Inputs, Outputs, Timers, Counters,

Relays, and System. The first pull-down select box is used to choose the category you want to edit. The default is always the Inputs.



The next pull-down box allows you to select which of the Inputs you want to edit. In ProSoft digital Inputs are called labeled as I with the number of the input, so Input 8 is I8.

Once you have selected the Input you want to edit click on the name box with the mouse(not the pull-down arrow) and type in a new name. For example change Input 1 (IP1) to read START.

It is now possible to give this input a description by entering text in the description box.

Once you have completed a TAG you must click on the **Add** button to ensure the data you have entered is added to the project. This must be done before you start editing the next tag or the data you have just entered will be lost.


Once you have completed edit the tag names and descriptions you must click on **Close** to exit this box.

It would be a good idea to save the project at this point by clicking the mouse on the **file->save** menu item.

3.7 EDIT->Communications

Now click on the menu item **Edit** and then **Communications**. If this option is available on the PLC you are using then a box will appear on the screen which is labeled Edit Modbus Communications.

If this feature is not available on your PLC then this option will not be available and you should go onto the next section.



When the Edit Modbus Communications box appears on the screen the Modbus Master select box will not be selected. This means that the PLC will be a Modbus slave. If you want the PLC to be a modbus slave, or you will not be using this communications option, then leave this box unselected and click on the **Close** button to exit the box.

When you select the Modbus master box the setup table will become active. This box allows you to configure up to 20 modbus poll blocks. This means that the PLC will be a Modbus Master and will be able to read or write modbus registers with up to 20 other Modbus slave devices. These devices could be other PLC's, Mod-MUX I/O modules or operator interface's etc.

The first column in the table is the Modbus Address(ID) of the slave that the PLC is going to communicate with. This value can range from 1 to 253 and will depend on the addressing capability of the slave unit.

The second column is the modbus function. Enter a 3 if you want to read registers from a remote slave unit, or 16 if you want to write to registers in a remote slave unit. Note that digital I/O must be read or written as 16 bit modbus registers.

The third column is the local address. This is the address of the memory in the PLC where values are to be written to (function 3) or read from (function 16) depending on the function.

See the Memory map of the PLC in the manual for the PLC that you are using to get the correct address for these registers.

The forth column is the range of the registers. This is the number of registers to be read or written.


The fifth column is the remote address. This is the address of the memory in the slave unit where values are to be read from (function 3) or written to (function 16). You will need to refer to the memory map of these registers in the manual for the slave unit.

Once you have completed entering the data into the table you must click on the **Submit** button to enter them into the project. Finally when you are complete you can click on the **Close** button to exit this box.

3.8 EDIT->Comms Settings

Now click on the menu item **Edit** and then **Comms Settings**. If this option is available on the PLC you are using then a box will appear on the screen which is labeled Setup PLC RS485 Comms Port.

If this feature is not available on your PLC then this option will not be available and you should go onto the next section.



The parameters which are setup in this box are not for the programming port on the PLC, but the second port which is used for RS485 Modbus Communications.

The Network ID is default to 1 and this is suitable for Modbus Master communications. If the PLC is to be a Modbus slave then this ID must be changed so that the PLC has a unique ID on the RS485 network. Valid addresses are from 1 to 253.

The baud rate, parity and stop bits must be setup to match the parameters of the RS485 network. Default values are baud rate = 19200, 8 data bits, no parity and 1 stop bit.

Once the values have been selected with the pull-down bars the data can be entered into the project by clicking on the **Select** button.

4. LADDER PROGRAMMING

4.1 LADDER TOOLBAR ELEMENTS.

The toolbar on the screen contains a collection of elements which may be chosen for generating the ladder diagram. The element must first be selected by clicking on it with the mouse. If you position the mouse pointer over the element a text description will pop up on the screen and if you click the mouse button over the element the text status bar at the bottom of the screen will show the element that has been chosen.

To add the element to the program you must move the mouse to the desired position on the ladder diagram area and click the mouse button. The element will be added to the ladder program. If there are options for this element then another box will open up on the screen for you to make further selections. A brief description of the elements are given below. A more detailed description can be found further in the manual.

4.1.1 Horizontal Wire

The horizontal wire is used to connect elements of the ladder diagram together from left to right and makes a series (AND) connection. It is the same as using a wire jumper in an electric circuit. For a circuit to be complete, there must be a continuous connection from the left hand side of the ladder diagram to the right hand side of the ladder diagram.

4.1.2 Vertical Wire

The vertical wire is used to connect elements of the ladder diagram together from top to bottom and makes a parallel (OR) connection. It is the same as using a wire jumper in an electric circuit.

4.1.3 Normally Open Contact

The normally open contact is equivalent to a relay contact or switch contact. In the PLC the normally open contacts may be inputs, outputs, timers, counters, internal relays in memory, or system statuses. The contact represents a single binary bit which is either off (0) or on (1).

4.1.4 Normally Closed Contact

The normally closed contact is equivalent to a relay contact or switch contact except that the status is inverted. If an input is on then the normally closed contact will be off.

4.1.5 Positive Edge Contact

The positive edge contact is a normally open contact which closes for a single PLC scan when the normally open contact goes from open to close. This contact is often called a “one-shot”.

4.1.6 Negative Edge Contact

The negative edge contact is a normally open contact which closes for a single PLC scan when the normally open contact goes from close to open. This contact is often called a “one-shot”.

4.1.7 Function Contact

The function contact enables the ladder program to do complex functions which have a Boolean result.

4.1.8 Normal Output

The normal output represents a physical output or could be an internal relay in memory in the PLC. The output is turned off if the result of the ladder rung connected to the output is off, or turned on if the result of the ladder rung is on.

4.1.9 Inverted Output

The inverted output is the same as the normal output except that if the ladder rung is off then the output will be on.

4.1.10 Set Output

The set output represents a physical output or could be an internal relay in memory in the PLC which is turned on when the ladder rung goes from off to on. If the rung goes from on to off then the output will remain latched on.

4.1.11 Reset Output

The reset output represents a physical output or could be an internal relay in memory in the PLC which is turned off when the ladder rung goes from off to on. If the rung goes from on to off then the output will remain off (unlatched).

4.1.12 Function Output

The function output represents a function block which may contain a timer, counter or other mathematical function. This function will only be executed if the rung is on.

4.1.13 Comment

The comment toolbar enables you to enter a text comment onto the ladder program. Comments are normally used to describe the operation of the following ladder circuit and are very useful for explaining to a third party the operation of a circuit.

4.1.14 Delete Element

When the delete element toolbar is firstly selected from the toolbar, and then any element on the ladder program can be deleted by clicking the mouse pointer over that element.

4.1.15 Delete Line

The delete line toolbar is used to delete all the elements on a complete line on the ladder program. The arrows coming together show the line being deleted and the program being shifted to close the gap.

4.1.16 Insert Line

The insert line toolbar is used to insert an empty line on the ladder program. The arrows facing apart show the ladder program being shifted apart to make space for the new line.

4.1.17 Copy Lines

The copy line toolbar is used to copy one or more lines from a part of the ladder program to another part. This is useful to save time re-entering repetitive lines of ladder program.

4.1.18 Move Lines

The move line toolbar is used to move one or more lines from a part of the ladder program to another part. This is useful if it is necessary to re-order the sequence of the ladder program and saves you from having to re-enter the program.

4.1.19 Shift Element Right

The shift element right toolbar is used to move the selected element one position to the right. This task will only be performed if the position on the right is not already occupied.

4.1.20 Shift Element Left

The shift element left toolbar is used to move the selected element one position to the left. This task will only be performed if the position on the left is not already occupied.

4.2 CREATING A SAMPLE PROGRAM.

The following example takes you through the steps of creating a simple ladder program. You may need to refer back to the previous chapters for some of the actions.

4.2.1 Step 1








Create a new project called sample1. Click the mouse pointer on **File->New** on the menu and after selecting the PLC type you are using type in the name sample1.


4.2.2 Step 2

Edit some tag names to make them more descriptive. Click on **Edit->Tags** on the menu and select Input 1. Change the name to START and click the **ADD** button. Select Input 2 and change the name to STOP and click the **ADD** button. Finally select Output 1 and change the name to FAN1, and click the **ADD** button. Click **Close** to exit. Click on **File->Save** to save the project.

4.2.3 Step 3

In this step you will enter a ladder program using the element toolbar.

- Click on the normally open contact  toolbar. Now click on the ladder program Row1,Column1. Select the START input from the box.
- Click on the horizontal wire  toolbar. Now click on the ladder program Row1,Column2.
- Click on the normally closed contact  toolbar. Now click on the ladder program Row1,Column3. Select the STOP input from the box.
- Click on the normally open contact  toolbar. Now click on the ladder program Row2,Column1. Select the FAN1 output from the box.
- Click on the vertical wire  toolbar. Now click on the ladder program Row2,Column2.
- Click on the horizontal wire  toolbar. Now click on the ladder program Row1,Column4 to Row1,Column12.
- Finally click on the normal output  toolbar. Now click on the ladder program Row1,Column13. Select the FAN1 output from the box.
- Click on the menu item **File->Save** to save the project.



The operation of the ladder program works as follows: The initial condition at power-up is that the START input is open, the FAN1 output is off and the STOP input is closed as it is a normally closed input. When the START input is closed, the rung is complete along Row1 from the left to the right. This results in the output FAN1 coming on. The FAN1 contact now closes and keeps the FAN1 switched on, even when the START input is off. When the STOP input is operated the circuit is broken and the FAN1 output switches off. This causes the FAN1 contact to open, so when the STOP input is removed, the FAN1 output stays off.

The example1 is a typical example of a start/stop circuit that would normally be implemented with relays. The circuit shown is called a rung. When a new circuit is programmed below the first circuit, a new rung will be created. Although these rungs form part of the same ladder program, they are treated as independent circuits.

5. COMPILING

The ladder program can now be compiled by clicking the mouse pointer on the **Compile** menu item. The text status line at the bottom of the screen will tell you when the compile process is complete.


The compile process is used to firstly check the program for errors, and secondly to convert the program into a format that the PLC understands.

If the ladder program has an incomplete circuit, then the compiler will give an error message and jump to the place on the program where the error is.

6. PROGRAMMING THE PLC

Once the ladder program has been successfully compiled, the PLC can be programmed with the ladder program. This is done by clicking the on the **Program** menu item.

Before the PLC can be programmed you must make sure that the PLC has been switched on and the Programming Port of the PLC has been connected to the RS232 COM port of the PC using the special programming cable from Procon.




When you start programming the PLC the software checks that the PLC type is the same as the type you selected for your project. If the types are not the same an error message will be displayed and programming will be aborted.

As soon as the programming is complete, the PLC will start running automatically. If you switch on the START input you will see that the FAN1 output stays latched on. If you switch on The STOP input you will see the FAN1 output switch off. This action can also be monitored on the PC if you now go into DEBUG mode.

7. DEBUGGING THE PLC

To enter Debug mode click the mouse pointer on the **Debug** menu item. If you switch on the START input you will see that the circuit is complete from left to right across the ladder program and this is shown by a red line on the screen. Any part of the circuit that is on will be in red. Any part that is off will not have the red line. If you now switch off the START input you will see that the circuit is being latched on by the FAN1 contact. The diagram below shows the red line where the circuit is complete. To go back to edit the ladder program click the mouse pointer on the **Ladder** menu item and this will stop the debug mode.



7.1 View I/O status in Debug Mode.

If you click the mouse pointer on the **PLC->View I/O** menu item a box will open which shows a list of the digital I/O in the PLC. You can use the scroll bar to move up or down the list. When a digital input/output is OFF it is in red and when it is ON it is in green. The purpose of this box is to show you the status of any of the digital inputs whilst the PLC is running. This is a very useful tool for fault finding your ladder program.


Try switching the START input on and off slowly and you will see the status change on the screen.

It is possible to toggle the state of an output by double clicking the mouse in the state column. If the state is OFF, then a command will be sent to the PLC to turn the output on. Once the output has turned on, the state will change to ON. Note that you cannot toggle the state of an input or system value.

7.2 View Memory in Debug Mode.

If you click the mouse pointer on the **PLC->View Mem** menu item a box will open which shows a list of the memory registers in the PLC. You can use the scroll bar to move up or down the list. The list does not have pre-defined values as with the I/O box. The reason for this is to give you flexibility in what you view on the screen at any one time. For instance you might want to view the current value of timer 1 which might be in memory address 12.(refer to the memory map of your PLC to get the correct address). Type 12 into the first column and you will see the current value automatically change in the value column. If you now want to view a value your program has in memory address 98 you would enter the number 98 into the second row, first column and the corresponding value will be shown in the value column.

If you want to alter the value of a memory location, then all you have to do is double click the mouse in the value column. This action will bring up another box which allows you to enter a new value from the keyboard. Clicking the mouse pointer on the **Update** button will write the new value to the PLC memory. Try changing the value in memory address 98 to 1234.



7.3 Start/Stop PLC in Debug Mode.

When you are in debug mode it is possible to stop the PLC and then start the PLC again by clicking the mouse pointer on the **PLC->Start PLC** or **PLC->Stop PLC** menu items. You can still view all the memory addresses and I/O statuses when the PLC has been stopped.


8. LADDER LOGIC

This section explains the layout of the memory, the layout of a ladder program and each of the elements that can be used in a ladder program.

8.1 PLC Operation.

When the PLC is running a program it runs in a continuous loop. Each pass around the loop is called a CPU SCAN. The scan time consists of the time taken to read the inputs, run the ladder program, write the outputs, and to do housekeeping work such as updating the timers, handling the communications and any other PLC specific tasks.

The diagram below shows a typical PLC scan cycle.




- The PLC reads the inputs from the physical hardware and copies their values to memory. The PLC ladder program uses the information from memory. This makes the PLC faster and avoids cases where an input changes from the start to the end of the program.
- The PLC steps through the ladder program one rung at a time. The program reads the inputs from memory and after performing the programmed tasks, the output memory is updated with the output information.
- When the program is complete the physical outputs are updated from the output memory.

The scan time is the time to go once through all of these steps. The part of the scan cycle that is within the control of the programmer is the ladder program. A short ladder program will result in fast scan times whilst more complicated programs which make use of many mathematical functions will take longer. It is up to the programmer to be aware of the response required for the system and to design the program accordingly.

8.2 PLC Memory.

The PLC has a block of memory which is used to store the statuses of inputs, outputs, timers, counters, internal relays, system relays, and variables. The size of the memory depends on the PLC that is being used. You will need to refer to the manual on your PLC to get the exact details.

Each element is identified by a Symbol and an Address.



There are three types of elements.

1. Relay elements: These operate in a similar way to a relay and their state is either ON or OFF.
2. Memory elements: These are 16 bit memory registers and are represented as numbers 0 – 65535.
3. Combination elements: These include Counters and Timers which have both relay and memory elements.

PLC Memory Map			
Element Type	Symbol	Address Range	Description
Inputs	I	1 – max Inputs	Used as a contact in the ladder program. Is connected to the physical inputs on the PLC.
Outputs	O	1 – max Outputs	Used as a contact or relay in the ladder program. Is connected to the physical outputs on the PLC.
Timers	T	1 – max Timers	Uses Memory for the Current Value and Preset Value. Uses contacts for the compare output.
Counters	C	1 – max Counters	Uses Memory for the Count Value and Preset Value. Uses contacts for the compare output.
Relays	R	1 – max Relays	May be used as temporary contacts or relays. Does not have any physical connection to inputs or outputs.
System	S	1 – max System	These are contacts which are generated by the PLC such as 1sec pulse contact, etc. Refer to manual on PLC.
Memory	M	0 – max Mem	Memory is used to store temporary variables for calculations using the output function element.
Constant	K	0 – 65535	Decimal Constant.

A typical memory map of a PLC would look like to following example.


Memory Address	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0	Element Type
M0									I 8	I 7	I 6	I 5	I 4	I 3	I 2	I 1	INPUT
M1													O 4	O 3	O 2	O 1	OUTPUT
M2	T16	T15	T14	T13	T12	T11	T10	T 9	T 8	T 7	T 6	T 5	T 4	T 3	T 2	T 1	TIMERS
M3	C16	C15	C14	C13	C12	C11	C10	C 9	C 8	C 7	C 6	C 5	C 4	C 3	C 2	C 1	COUNTER
M4	R16	R15	R14	R13	R12	R11	R10	R 9	R 8	R 7	R 6	R 5	R 4	R 3	R 2	R 1	RELAYS
M5	R32	R31	R30	R29	R27	R27	R26	R25	R24	R23	R22	R21	R20	R19	R18	R17	RELAYS
M6	S16	S15	S14	S13	S12	S11	S10	S 9	S 8	S 7	S 6	S 5	S 4	S 3	S 2	S 1	SYSTEM
M7																	TIMER1
M8																	TIMER2
M9																	TIMER3
M10																	"
M11																	TIMER16
M12																	COUNTER 1
M13																	COUNTER 2
M14																	COUNTER 4
M15																	"
M16																	COUNTER16
M17																	USER MEM
M18																	USER MEM
M19																	USER MEM
M20																	"
M21																	"
M22																	"
M23																	"

8.3 Basic Rung Configurations.


The program is made up with input elements in columns 1 to 12 and output elements in the final column 13. A complete circuit may use only one or may use many rows. This circuit is called a rung.

Some basic configurations of rungs are shown below.


- The example below shows a simple rung with a single Input and Output.




- It is not always necessary for a rung to have an input contact. If the program is used to always switch an output on then the rung would look like this. It is essential that each rung has at least one output relay or an output function, otherwise the circuit would do nothing.




- It is not always necessary to have an **END** output function at the end of a program except if the program uses subroutines. Subroutines are placed after the end function and are only run if called by the ladder program. You can also use an **END** in the middle of a program if you only want to test a portion of the program. Any rungs after the **END** will be ignored.




- Input contacts can be put in series. This is known as an and function. For example in the diagram below, Input 1 **AND** Input 2 must be on for the Output 1 to go on.



- Input contacts can be put in parallel. This is known as an or function. For example in the diagram below, Input 1 **OR** Input 2 must be on for the Output 1 to go on.




- A row can be split so that outputs can also be put in parallel. This is used when the same condition is used to switch more than one output. For example in the diagram below, Input 1 will turn on Output 1 **AND** OUTPUT 2.



- It is also possible to put input contacts in the split. For example in the diagram below, Input 1 will turn on Output 1. Input 1 **AND** Input 2 will turn on OUTPUT 2.





- The series and parallel ladder circuits can be combined into a single rung. For example in the diagram below, the Output 1 will turn on if either Input 1 **AND** Input 2 is on, **OR**, Input 3 **AND** Input 4 is on.



8.4 Ladder Program Processing.

When the PLC runs the ladder program it steps through each of the elements starting at the top left and ending at the bottom right. When the PLC gets to the END of the program it starts from the beginning again.

The example below shows the typical sequence of processing a program.




8.5 Ladder Programming Elements.

This section gives a detailed explanation of the elements that you can use to create your ladder program.


8.5.1 Ladder Inputs - Normally Open/Closed Contact

The normally open contact is equivalent to a relay contact or switch contact. It can either be in the on or off state, and can be a physical input or output, or a point in memory. The normally closed contact is simply the inverse of a normally open contact.

In the following example, when input I1 is on the output O1 will go on.




In the following example, when input I1 is off the output O1 will go on.




8.5.2 Ladder Inputs - Positive/Negative Edge Contact

The positive edge contact is a normally open contact which closes for a single PLC scan when the normally open contact goes from off to on. The negative edge contact closes for a single PLC scan when the normally open contact goes from on to off.

In the following example, each time input I1 goes from off to on, the output O1 will go on for one scan.



In the following example, each time input I1 goes from on to off, the output O1 will go on for one scan.



8.5.3 Ladder Inputs – Function Contact

The function contacts are function blocks which produce an ON or OFF result and can be treated as a ladder input.

8.5.3.1 Function Contact – (Mem = Mem)

The function compares the contents of two memory locations. If they are the same then the result will be on otherwise the result will be off.

In the following example, when the value in memory M12 is equal to the value in memory M13 the output O1 will turn on.



8.5.3.2 Function Contact – (Mem = Const)

The function compares the contents of a memory location with a constant number. If they are the same then the result will be on otherwise the result will be off.


In the following example, when the value in memory M12 is equal to 10 the output O1 will turn on.



8.5.3.3 Function Contact – (Mem /= Mem)

The function compares the contents of two memory locations. If they are not the same then the result will be on otherwise the result will be off.


In the following example, when the value in memory M12 is not equal to the value in memory M13 the output O1 will turn on.



8.5.3.4 Function Contact – (Mem /= Const)

The function compares the contents of a memory location with a constant number. If they are not the same then the result will be on otherwise the result will be off.

In the following example, when the value in memory M12 is not equal to 10 the output O1 will turn on.



8.5.3.5 Function Contact – (Mem >= Mem)

The function compares the contents of two memory locations. If the value in the first memory is greater than or equal to the value in the second memory the result will be on otherwise the result will be off.


In the following example, when the value in memory M12 is greater or equal to the value in memory M13 the output O1 will turn on.



8.5.3.6 Function Contact – (Mem >= Const)

The function compares the contents of a memory location with a constant number. If the value in memory is greater than or equal to the constant then the result will be on otherwise the result will be off.

In the following example, when the value in memory M12 is greater or equal to 10 the output O1 will turn on.



8.5.3.7 Function Contact – (Mem < Mem)

The function compares the contents of two memory locations. If the value in the first memory is less than the value in the second memory the result will be on otherwise the result will be off.


In the following example, when the value in memory M12 is less than the value in memory M13 the output O1 will turn on.



8.5.3.8 Function Contact – (Mem < Const)

The function compares the contents of a memory location with a constant number. If the value in memory is less than the constant then the result will be on otherwise the result will be off.

In the following example, when the value in memory M12 is less than 10 the output O1 will turn on.




8.5.4 Ladder Outputs – Normal/Inverted Output

The normal output represents a physical output or could be an internal relay in memory in the PLC. The output is turned off if the result of the ladder rung connected to the output is off, or turned on if the result of the ladder rung is on. The inverted output is simply the inverse of a normal output.

In the following example, when input I1 is on the output O1 will go on.



In the following example, when input I1 is on the output O1 will be off.




8.5.5 Ladder Outputs – Set/Reset Output

The set output represents a physical output or could be an internal relay in memory in the PLC which is turned on when the ladder rung goes from off to on. If the rung goes from on to off then the output will remain latched on. The reset output is simply the opposite and is turned off when the ladder rung goes from off to on.

In the following example, when input I1 goes on the output O1 will be set on. When input I1 is off the output O1 will stay on.



In the following example, when input I1 goes on the output O1 will be reset off. When input I1 is off the output O1 will stay off.



8.5.6 Ladder Outputs – Standard Functions

The function outputs are function blocks which perform a set task if the result of the rung is on.


8.5.6.1 Function Output – (Timer 0.1Sec & Timer 0.01Sec)

The Timer 0.1Sec is a single input timer with 0.1 Second time base and the Timer 0.01Sec has a 0.01Second time base. The functionality of these timers is the same.

There a number of timers available numbered from 1 upwards to the maximum depending on the PLC being used. The timer will run as long as the input is on. The timer will be reset to zero when the input is off.

The timer also has a built in compare function. The compare function compares the timer value with a value in memory or a constant. If the timer value is less than the memory value or constant then the timer output will be off, otherwise it will be on.

In the example below, the timer T1 will start timing when the input I1 is turned on. When the timer value is greater or equal to 40 (4 seconds) the timer output will turn on. When the input I1 turns off (after 6 seconds), the timer T1 will stop and the timer value will be reset to zero.





8.5.6.2 Function Output – (TimerA 0.1Sec and TimerA 0.01Sec)

The TimerA 0.1Sec is an Accumulating timer with 0.1 Second time base and the TimerA 0.01Sec has a 0.01Second time base. The functionality of these timers is the same.

There a number of timers available numbered from 1 upwards to the maximum depending on the PLC being used. The timer will run as long as the input is on and stops when the input is removed. The timer will continue when the input is on again. The timer will be reset to zero when the reset input is on.

The timer also has a built in compare function. The compare function compares the timer value with a value in memory or a constant. If the timer value is less than the memory value or constant then the timer output will be off, otherwise it will be on.


In the example below, the timer T1 will start timing when the input I1 is turned on. If input I1 is turned off then the timer will stop. The timer will continue when the input is turned on again. When the timer value is greater or equal to 40 (4 seconds) the timer output will turn on. When the input I2 turns on (after 6 seconds), the timer T1 will stop and the timer value will be reset to zero.



8.5.6.3 Function Output – (Counter)

Up counter with reset input. The counter will count up when the count input goes from off to on. The counter will be reset to zero when the reset input is on. The counter output will go on when the count value is greater or equal to the preset value. The counter is addressed as the counter number from 1 to max Counters depending on the PLC being used.

In the example below, the counter C1 will increment on each off to on transition of the input I1. When the counter value is greater or equal to 4 the counter output will turn on. When the input I2 turns on, the counter C1 will stop and the counter value will be reset to zero.



8.5.6.4 Function Output – (Cntr Up/Down – Type 1)

Up/Down counter with reset input. The counter will count up when the Up count input goes from off to on. The counter will count down when the Down count input goes from off to on. The counter will be reset to zero when the reset input is on. The counter output will go on when the count value is greater or equal to the preset value.



In the example below, the counter C1 will increment on each off to on transition of the input I1. The counter C1 will decrement on each off to on transition of the input I2. When the counter value is greater or equal to 5 the counter output will turn on. When the input I3 turns on, the counter C1 will stop and the counter value will be reset to zero.



8.5.6.8 Function Output – (OUT)

The lower 16 bits of the value in the accumulator is copied to memory(M).



In the example, the value in the accumulator is copied to memory address 44.



8.5.6.9 Function Output – (AND)

This function logically AND's the lower 16 bits of the accumulator with memory(M) or with a constant(K). The result is placed in the accumulator.



If the memory M12 has the value: 0000 0000 0000 0011
 and the memory M44 has the value: 0000 0000 0000 0110
 the result copied to memory M44 will be: 0000 0000 0000 0010.



8.5.6.11 Function Output – (XOR)

This function logically Exclusive OR's the lower 16 bits of the accumulator with memory(M) or with a constant(K). The result is placed in the accumulator.

If the memory M12 has the value: 0000 0000 0000 0011
 and the memory M44 has the value: 0000 0000 0000 0110
 the result copied to memory M44 will be: 0000 0000 0000 0101.



8.5.6.12 Function Output – (CMP)

This function Compares the accumulator lower 16 bits with memory(M) or with a constant(K). If the value in the accumulator is less than the value in memory/constant then system bit S6 is turned on. If the value in the accumulator is equal to the value in memory/constant then system bit S7 is turned on. If the value in the accumulator is greater than the value in memory/constant then system bit S8 is turned on. The value in the accumulator is left unchanged.


If the memory M12 has the value 123 and the memory M44 has the value 125 then the system bit S6 will be on and the system bits S7 and S8 will be off.



8.5.6.13 Function Output – (ADD)

This function Adds the memory(M) or constant(K) to the accumulator. The result is stored in the accumulator.


$$ACC = ACC + M/K$$



8.5.6.14 Function Output – (SUB)

This function subtracts the memory(M) or constant(K) from the accumulator. The result is stored in the accumulator.


$$ACC = ACC - M/K$$



8.5.6.15 Function Output – (MUL)

This function multiplies the accumulator with the memory(M) or constant(K). The result is stored in the accumulator. The result can be a value up to 32 bits.


$$ACC = ACC \times M/K$$



8.5.6.16 Function Output – (DIV)

This function divides the 32 bit accumulator by the 16 bit memory(M) or constant(K). The result is stored in the accumulator.


$$ACC = ACC / M/K$$



8.5.6.17 Function Output – (INC)

This function increments the memory(M) directly and does not use the accumulator.


$$Mem = Mem + 1$$



8.5.6.18 Function Output – (DEC)

This function decrements the memory(M) directly and does not use the accumulator.


$$Mem = Mem - 1$$



8.5.6.19 Function Output – (INV)

This function inverts the bits in the accumulator.


$$ACC = \sim ACC$$



8.5.6.20 Function Output – (MOV)


This function moves a variable in a memory location to a new location. The accumulator must already contain the address of the memory location to be moved.

$$M44 = M43$$




8.5.6.21 Function Output – (SHL)

The bits in the accumulator are shifted left by the value in memory(M) or constant(K). The lower bits are filled with zeros. In the example below, the accumulator is loaded with the value 5 or 0000 0000 0000 0101 binary. The accumulator is then shifted left 3 times to give the result 40 or 0000 0000 0010 1000 binary.



8.5.6.22 Function Output – (SHR)

The bits in the accumulator are shifted right by the value in memory(M) or constant(K). The upper bits are filled with zeros. In the example below, the accumulator is loaded with the value 5 or 0000 0000 0000 0101 binary. The accumulator is then shifted right twice to give the result 1 or 0000 0000 0000 0001 binary.



8.5.6.23 Function Output – (CALL)

This function is used to call a subroutine. The constant(k) is the label of the subroutine.


8.5.6.24 Function Output – (SUBR)

This function is the start of a subroutine. The constant(k) is the label of the subroutine which is called by the call function.

8.5.6.25 Function Output – (RET)


This function must be placed at the last line of a subroutine. The function can also be used in the subroutine for a conditional return.

The example below calls a subroutine number 1 when input 1 is on. The subroutine SUBR ladder diagram is placed after the END function and labels the start of the subroutine. The RET function is used to tell the PLC that this is the end of the subroutine and to jump back to the main program. A maximum of 20 subroutines can be used in a ladder program.



8.5.6.26 Function Output – (RAND)

This function places a random number from 0 to 100 in the accumulator.



8.5.7 Ladder Outputs – Advanced Functions


The advanced function outputs are function blocks which perform advanced tasks. You must check the manual for your PLC to see which of these functions are available in your PLC.

8.5.7.1 Function Output – (LDD Load Double)

The accumulator is a 32 bit working register which is used for all mathematical operations. The accumulator must first be loaded with a value before any of the mathematical functions are used.

The LDD function loads the 32 bit accumulator from memory(M) or with a constant(K). As memory is only 16 bit registers, the LDD function loads the lower 16 bits of the accumulator from the memory location (M) and the upper 16 bits from the memory location (M+1).


The example loads the lower 16 bits of the accumulator with the value in memory address 12 and the upper 16 bits of the accumulator with the value in memory address 13. Note that if the function is joined directly to the left hand side of the rung, that the function will be called every PLC scan.



8.5.7.2 Function Output – (OUTD Out Double)

The lower 16 bits of the accumulator are copied to the memory (M) and the upper 16 bits of the value in the accumulator are copied to memory(M+1).


In the example, the lower 16 bits of the accumulator are copied to memory address M44 and the upper 16 bits to memory M45.



8.5.7.3 Function Output – (ANDD)

This function logically AND's the accumulator with memory(M) and memory(M+1) or with a constant(K). The result is placed in the accumulator.


If the accumulator has the value: 0000 0000 0000 1100 0000 0000 0000 0011
 and memory M44 has the value: 0000 0000 0000 0110
 and memory M45 has the value: 0000 0000 0001 1000
 the result in the accumulator: 0000 0000 0000 1000 0000 0000 0000 0010



8.5.7.4 Function Output – (ORD)

This function logically OR's the 32 bit accumulator with memory(M) and memory(M+1) or with a constant(K). The result is placed in the accumulator.


If the accumulator has the value: 0000 0000 0000 1100 0000 0000 0000 0011
 and memory M44 has the value: 0000 0000 0000 0110
 and memory M45 has the value: 0000 0000 0001 1000
 the result in the accumulator: 0000 0000 0001 1100 0000 0000 0000 0111



8.5.7.5 Function Output – (XORD)

This function logically Exclusive OR's the 32 bit accumulator with memory(M) and memory(M+1) or with a constant(K). The result is placed in the accumulator.


If the accumulator has the value: 0000 0000 0000 1100 0000 0000 0000 0011
 and memory M44 has the value: 0000 0000 0000 0110
 and memory M45 has the value: 0000 0000 0001 1000
 the result in the accumulator: 0000 0000 0001 0100 0000 0000 0000 0101



8.5.7.6 Function Output – (CMPD)

This function Compares the 32 bit accumulator with memory(M) and (M+1) or with a constant(K). If the value in the accumulator is less than the value in memory/constant then system bit S6 is turned on. If the value in the accumulator is equal to the value in memory/constant then system bit S7 is turned on. If the value in the accumulator is greater than the value in memory/constant then system bit S8 is turned on. The value in the accumulator is left unchanged.

If the memory M12 has the value 123 and the memory M44 has the value 125 then the system bit S6 will be on and the system bits S7 and S8 will be off.



8.5.7.7 Function Output – (ADDD)

This function Adds the memory(M) and (M+1) or constant(K) to the 32 bit accumulator. The result is stored in the accumulator.

$$ACC = ACC + M+1/M \quad \text{or} \quad ACC = ACC + K$$

8.5.7.8 Function Output – (SUBD)

This function Subtracts the memory(M) and (M+1) or constant(K) from the 32 bit accumulator. The result is stored in the accumulator.

$$ACC = ACC - M+1/M \quad \text{or} \quad ACC = ACC - K$$

8.5.7.9 Function Output – (MULD)

This function Multiplies the memory(M) and (M+1) or constant(K) with the 32 bit accumulator. The result is stored in the accumulator.

$$ACC = ACC \times M+1/M \quad \text{or} \quad ACC = ACC \times K$$

8.5.7.10 Function Output – (DIVD)

This function divides the 32 bit accumulator by the memory(M) and (M+1) or constant(K). The result is stored in the accumulator.

$$ACC = ACC / M+1/M \quad \text{or} \quad ACC = ACC / K$$

8.5.7.11 Function Output – (INCD)

This function increments the memory(M) and (M+1) directly and does not use the accumulator.

$$(M+1/M) = (M+1/M) + 1$$

8.5.7.12 Function Output – (DECD)


This function decrements the memory(M) and (M+1) directly and does not use the accumulator.

$$(M+1/M) = (M+1/M) - 1$$

8.5.8 Ladder Outputs – Float Functions

The float functions are function blocks which perform mathematical tasks using the IEEE 754 floating point notation. These functions use two memory locations and are 32 bit functions. The range of the values extend from +/- 1.18E-38 to +/- 3.39E+38.

The 32 bit floating point format is as follows:



The value of the number is:

$$(-1)^S * 2^{(\text{Exponent} - 127)} * 1.\text{Mantissa}$$

Float Constants can be written with or without the exponential. For example 123.4 can also be written as 1.234E2.

You must check the manual for your PLC to see which of these functions are available in your PLC.

8.5.8.1 Function Output – (LDF Load Float)

The floating point functions use a separate accumulator which must first be loaded with a value before any of the floating point mathematical functions are used.

The LDF function loads the 32 bit float accumulator from memory(M) or with a constant(F). As memory is only 16 bit registers, the LDF function loads the lower 16 bits of the accumulator from the memory location (M) and the upper 16 bits from the memory location (M+1).

8.5.8.2 Function Output – (OUTF Out Float)

The OUTF function copies the 32 bit float accumulator to memory(M). As memory is only 16 bit registers, the OUTF function copies the lower 16 bits of the accumulator to the memory location (M) and the upper 16 bits to the memory location (M+1).

8.5.8.3 Function Output – (CMPF Compare Float)

This function Compares the 32 bit float accumulator with memory(M) and (M+1) or with a constant(K). If the value in the accumulator is less than the value in memory/constant then system bit S6 is turned on. If the value in the accumulator is equal to the value in memory/constant then system bit S7 is turned on. If the value in the accumulator is greater than the value in memory/constant then system bit S8 is turned on. The value in the accumulator is left unchanged.

8.5.8.4 Function Output – (ADDF)

This function Adds the memory(M) and (M+1) or constant(F) to the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = FACC + M+1/M \quad \text{or} \quad FACC = FACC + F$$

8.5.8.5 Function Output – (SUBF)

This function Subtracts the memory(M) and (M+1) or constant(F) from the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = FACC - M+1/M \quad \text{or} \quad FACC = FACC - F$$

8.5.8.6 Function Output – (MULF)

This function Multiplies the memory(M) and (M+1) or constant(F) with the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = FACC \times M+1/M \quad \text{or} \quad FACC = FACC \times F$$

8.5.8.7 Function Output – (DIVF)

This function divides the 32 bit float accumulator by the memory(M) and (M+1) or constant(F). The result is stored in the float accumulator.

$$FACC = FACC / M+1/M \quad \text{or} \quad FACC = FACC / F$$

8.5.8.8 Function Output – (BTOF)

This function copies the 32 bit accumulator to the 32 bit float accumulator. A type conversion is carried out from a 32 bit integer to a 32 bit floating point value.

$$FACC = ACC$$

8.5.8.9 Function Output – (FTOB)

This function copies the 32 bit floating point accumulator to the 32 bit accumulator. A type conversion is carried out from a 32 bit floating point value to a 32 bit integer.

$$ACC = FACC$$

8.5.8.10 Function Output – (PWRF)

This function raises the 32 bit float accumulator by the power of the value in memory(M) and (M+1) or constant(K). The result is stored in the float accumulator.

$$FACC = FACC^{(M+1/M)} \quad \text{or} \quad FACC = FACC^{(F)}$$

8.5.9 Ladder Outputs – Trigonometric Functions

The trig functions are function blocks which perform mathematical tasks using the IEEE 754 floating point notation. The unit for the functions is in RAD's.

You must check the manual for your PLC to see which of these functions are available in your PLC.

8.5.9.1 Function Output – (ACOSF)

This function performs the Arc Cosine of the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = ACOS(FACC)$$

8.5.9.2 Function Output – (ASINF)

This function performs the Arc Sine of the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = ASIN(FACC)$$

8.5.9.3 Function Output – (ATANF)

This function performs the Arc Tangent of the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = ATAN(FACC)$$

8.5.9.4 Function Output – (COSF)

This function performs the Cosine of the 32 bit float accumulator. The result is stored in the float accumulator.

$$FACC = COS(FACC)$$

8.5.9.5 Function Output – (SINF)

This function performs the Sine of the 32 bit float accumulator. The result is stored in the float accumulator.

$$\text{FACC} = \text{SIN}(\text{FACC})$$

8.5.9.6 Function Output – (TANF)

This function performs the Tangent of the 32 bit float accumulator. The result is stored in the float accumulator.

$$\text{FACC} = \text{TAN}(\text{FACC})$$

8.5.9.7 Function Output – (SQRTF)

This function performs the square root of the 32 bit float accumulator. The result is stored in the float accumulator.

$$\text{FACC} = \text{SQRT}(\text{FACC})$$

8.5.9.8 Function Output – (RADF)

This function converts the degree value of the 32 bit float accumulator to the radian. The result is stored in the float accumulator.

$$\text{FACC} = \text{RAD}(\text{FACC})$$

8.5.9.9 Function Output – (DEGF)

This function converts the radian value of the 32 bit float accumulator to degrees. The result is stored in the float accumulator.

$$\text{FACC} = \text{DEG}(\text{FACC})$$

8.5.9.10 Function Output – (LOGF)

This function performs the logarithmic function on the value in the 32 bit float accumulator. The result is stored in the float accumulator.

$$\text{FACC} = \text{LOG}(\text{FACC})$$

8.5.9.11 Function Output – (EXPF)

This function performs the exponential function on the value in the 32 bit float accumulator. The result is stored in the float accumulator.

$$\text{FACC} = \text{EXP}(\text{FACC})$$

8.5.10 Ladder Outputs – Communications Functions

8.5.10.1 Function Output – Serial Communications – (COMM)

The RS485 communications port can be controlled directly from the ladder logic program instead of using the Modbus Poll Blocks as previously described. The Modbus Master tick box must not be selected. This puts the RS485 communications port in Modbus Slave mode until the COMM function is called.

The communications function COMM is used to setup the parameters and to initiate a communications poll which could be a read or a write. Some of the parameters are initialized to default values on power up of the PLC. If you do not need to change these parameters then you do not need to include them in the ladder logic program. Other parameters are kept after the first communications poll has been completed, so if the value does not change then it is not necessary to reload them each time.

The parameters are listed below:

Serial Communications Parameters		
Parameter	Name	Description
0	Port Number	Select the RS485 Port (Default = 1)
1	Protocol	Modbus = 0, Memory = 1 (Default = 0)
2	Slave ID	The network address of the slave device.
3	PLC Memory Address	This is the address of the memory in the PLC where values are to be written to or read from, depending on the function. See the Memory map of the PLC in the manual for the PLC that you are using to get the correct address for these registers.
4	Range	This is the number of registers to be read or written.
5	Slave Memory Address	This is the address of the memory in the slave unit where values are to be read from or written to. You will need to refer to the memory map of these registers in the manual for the slave unit.
6	Timeout	This is the time that the communications driver will wait for a response from the slave device before a timeout error occurs. The time is a multiple of 10 milliseconds.
7	Function	This is the Modbus function that determines if the poll is a read or a write. The following functions are supported: 1 - Read a range of bits. 3 - Read a range of registers 15 - Write a range of bits. 16 - Write a range of registers. This parameter must always be the last parameter called as it also starts the communications transmission.


There are two system bits that are associated with the communications port. These are the CommReady bit and the CommError bit.

The CommReady bit is normally off and will indicate that the communications port is ready for a new message. As soon as the new message has started transmitting, this bit is set to on. This bit is used in the ladder logic program to prevent a second message from being sent out before the previous message is complete. The example shows how it is used. The bit is cleared to off when the reply has been received from the slave. If no reply comes back, then the timeout will expire and the bit will be cleared off. The CommError bit will be set on to indicate an error.

COL 1 2 3 4 5 6 7 8 9 10 11 12 13


R O W
1

The first Poll will write a register from Memory Address 1 in the PLC to Memory Address 1 in the Slave with a Range of 1
Function 16 is used to write a range of registers.
Note how the Comm1Ready bit is used to ensure that the program only runs the functions when the Comm Port is ready



R O W
7

The second Poll will read a register from Memory Address 1 in the Slave to Memory Address 100 in the PLC with a Range of
Function 3 is used to read a range of registers.



R O W
13



8.5.10.2 Function Output – TCP/IP Communications – (TCOM)

The Ethernet communications port can be controlled directly from the ladder logic program to send Modbus TCP/IP or UDP messages to remote slave devices.


The communications function TCOM is used to setup the parameters and to initiate a communications poll which could be a read or a write. Some of the parameters are initialized to default values on power up of the PLC. If you do not need to change these parameters then you do not need to include them in the ladder logic program. Other parameters are kept after the first communications poll has been completed, so if the value does not change then it is not necessary to reload them each time.


The parameters are listed below:

TCP/IP and UDP Communications Parameters		
Parameter	Name	Description
0	Port Number	502 = MODBUS TCP/IP or MODBUS UDP
1	Protocol	Modbus = 0, Memory = 1 (Default = 0)
2	Slave ID	The network address of the slave device.
3	PLC Memory Address	This is the address of the memory in the PLC where values are to be written to or read from, depending on the function. See the Memory map of the PLC in the manual for the PLC that you are using to get the correct address for these registers.(Mxxx)
4	Range	This is the number of registers to be read or written.
5	Slave Memory Address	This is the Modbus address of the memory in the slave unit where values are to be read from or written to. You will need to refer to the memory map of these registers in the manual for the slave unit. ie: Modbus 40003 = 3.
6	Timeout	This is the time that the communications driver will wait for a response from the slave device before a timeout error occurs. The time is a multiple of 10 milliseconds.
7	Function	This is the Modbus function that determines if the poll is a read or a write. The following functions are supported: 1 - Read a range of bits. 3 - Read a range of registers 15 - Write a range of bits. 16 - Write a range of registers.
8	Mode	0 - TCP/IP 1- UDP This parameter must always be the last parameter called as it also starts the communications transmission.

There are two system bits that are associated with the communications port. These are the TComReady bit and the TComError bit.

The TComReady bit is normally off and will indicate that the communications port is ready for a new message. As soon as the new message has started transmitting, this bit is set to on. This bit is used in the ladder logic program to prevent a second message from being sent out before the previous message is complete. The example shows how it is used. The bit is cleared to off when the reply has been received from the slave. If no reply comes back, then the timeout will expire and the bit will be cleared off. The TComError bit will be set on to indicate an error.





9. LADDER PROGRAM EXAMPLES

This section describes some practical applications and how they can be implemented using the PLC. The purpose is to show you how ladder programs can be constructed and to see how the various elements are used.

9.1 Motor Control Example.

This example can be used for most applications for the control of motors via a PLC including pumps, conveyors, mixers, etc.

The START input must be held on for 5 seconds before the motor starts. The STOP input stops the motor. The Emergency Stop will stop the motor and stay latched until the Reset input is pressed.


The I/O used will be as follows:

Digital Input 1: START	Manual Start Push-Button
Digital Input 2: STOP	Manual Stop Push-Button
Digital Input 3: ESTOP	Emergency Stop, aux contact from emergency stop circuit.
Digital Input 4: RESET	Alarm reset Push-Button

Digital Output 1: MOTOR Motor run relay

Control Logic:


The first step is to do the detecting and latching of the emergency stop alarm. The alarm will only be cleared when the alarm condition is cleared and the operator resets the alarm. We use the internal relay R1 as the emergency stop alarm relay.



Next a timer with a limit of 5 seconds (50 X 0.1sec) is connected to the Start input. The timer output will switch on when the START input is pressed for longer than 5 seconds.



Finally we do the program which drives the output to the motor having considered all the input signals.



It is possible to add other alarm circuits for motor tripped and motor running feedback signals which use the Reset input in an identical manner to the emergency stop circuit above.

9.2 Garage Door Example.

It is required to design a ladder logic program to operate a garage door.

- There is a single pushbutton which is used to open or close the door. If the door is down then the button will start it opening. If the door is up then the button will start it closing. If the door is opening or closing then the door will stop and if the button is pressed again then the door must change direction.
- There is a limit switch at the top and bottom of the door to indicate when the door is up or down. The limit switch is closed when the door is in contact with it.
- The door motor requires two relays, one to make it go up and the other to make it go down.

The I/O used will be as follows:

Digital Input 1: BUTTON	Manual Push-Button (Normally open and non-latching)
Digital Input 2: TOP_L	Top limit switch
Digital Input 3: BOT_L	Bottom limit switch


Digital Output 1: UP	Motor run - UP
Digital Output 2: DOWN	Motor run - DOWN

Control Logic:


There are many ways of solving this program depending on the ladder elements chosen and on your personal style of programming. This example shows one of these solutions and gives an idea how a application problem can be solved step by step.

We start by programming a motor control circuit to operate the UP motor. When the BUTTON input is pressed the UP motor must turn on and stay latched on. The motor must turn off when the door hits the TOP limit switch or if there is a fault and the DOWN motor is on.


The same idea is applied to the DOWN motor. The motor will run until the door hits the BOTTOM limit switch.




The next step is to add the stop facility. We add a circuit that uses internal relay R5 as the STOP contact. The BUTTON can only be used to STOP the motor if the motor is already going up **OR** down. We also change the BUTTON contacts to a one-shot when the BUTTON is pressed. This prevents the circuit from generating a race condition if the button is held on. The STOP contact (R5) is added to the UP and DOWN motor control circuits.




The next thing we have to take care of is that the BUTTON must only operate the STOP relay if the motor has moved off the limit switch. In the circuit we add the two limit switch contacts in series with the UP and DOWN contacts.



The final problem to be solved is that when we stop the door mid-travel and then push the BUTTON to change direction, the door always UP. The reason for this is because the UP ladder circuit runs before the DOWN ladder circuit so the UP motor always turns on first. To solve this we need to remember which direction we were traveling in when we stopped the motor. This is done by adding another internal relay R3 which we call U/D_L or UP/Down latch. When the door goes UP we set this relay on. When the door goes down we reset this relay to off. If we now add the contact from this relay to be in series with the BUTTON for each of the motor controls then if the motor was going up the U/D_L normally closed contact will be open. This prevents the motor from going up again after a stop and so the down circuit can be operated.



Now try adding a timer so that a LIGHT on output 3 comes on for 10 seconds each time the button is pressed. The BUTTON sets the LIGHT on. This starts the timer. When the timer reaches the set point ($100 \times 0.1S = 10Sec$), the timer contact closes which resets the LIGHT to off and on the next scan the timer is stopped.



9.3 Up/Down Counter Example.

It is required to generate an up/down counter which has 2 up inputs and 2 down inputs. The counter must switch on a light when a maximum count of 1500 has been reached.

- The standard counter function block cannot be used as this only has 1 input for up and 1 input for down so we must use another technique.

The I/O used will be as follows:


Digital Input 1: UP1 Manual Push-Button
Digital Input 2: UP2 Manual Push-Button
Digital Input 3: DOWN1 Manual Push-Button
Digital Input 4: DOWN2 Manual Push-Button

Digital Output 1: LIGHT

Control Logic:

As it is not possible to use the built in counter function we need to make our own counter. Use memory M45 to store the counter value. Check that this memory is available on your PLC. If it is not then choose another memory address.

To implement the UP count we can use the INCREMENT (INC) function and to do the DOWN count we can use the DECREMENT (DEC) function. As we only want to count once every time the inputs go on, we need to use the positive edge contact (one-shot).



Now to switch on the light when the count reaches 1500 we can use the compare function as follows. Whenever the count goes over 1500 the light will come on and when the count goes back below 1500 then the light will go off.



